

**CENTRAL MAINE POWER COMPANY
RESPONSE TO COMPETITIVE ENERGY SERVICES' DATA REQUEST NO. 1
DOCKET No. 2008-255**

October 7, 2008

CES-01-01

- Q.** Please provide in excel format the actual 2006 load data and electrical load allocations at the substation bus level that are referenced on Page 1 of 9, paragraph 4.
- A.** The actual loads are shown in the NepochCaseLoads comparison shown in Exhibit B-2, Appendix C. The columns with the labels "P – EMS" and "Q – EMS" were from data retrieved from CMP's Master Satellite Energy Management System state estimator. The state estimator models the Maine Satellite control area transmission system and stores the 2006 peak load hour transformer loadings and generation levels. This data is available in the attached spreadsheet.

Response Prepared and Submitted By:

Rick Conant

RLC Engineering LLC