

**CENTRAL MAINE POWER COMPANY
RESPONSE TO COMPETITIVE ENERGY SERVICES' DATA REQUEST NO. 2
DOCKET No. 2008-255**

September 15, 2008

CES-02-18

- Q.** Please explain whether the reduction in losses referred to on Page 51 at line 5 are losses on the PTF System or losses on the non-PTF System.
- A.** The reduction in losses refers to the decrease in electric power consumed by the 345 kV and 115 kV transmission lines and 345/115 kV transformers of the Maine transmission system in the BHE and CMP service territories. These facilities consist of both *PTF* and non-*PTF* losses with the majority classified as *PTF*.

Response Prepared and Submitted By:

Rick Conant
RLC Engineering LLC