

**CENTRAL MAINE POWER COMPANY  
RESPONSE TO EXAMINER'S DATA REQUEST NO. 4  
DOCKET No. 2008-255**

**October 22, 2008**

**EX-04-03**

**Q.** (Volume VII, Page 4 of 573) Please supply the ratings for all 345/115kV transformers in Maine and the seacoast area of New Hampshire. In your response, please include temperature limits and loss of life used. If PP-7 was used to calculate ratings for the transformer, also include similar information for the previous ratings.

**A.** Please refer to Response EX-02-08 for the requested information.

**Response Prepared and Submitted By:**

Rick Conant  
Manager Power System Studies  
RLC Engineering, LLC