

**CENTRAL MAINE POWER COMPANY
RESPONSE TO EXAMINER'S DATA REQUEST NO. 13
DOCKET No. 2008-255**

July 13, 2009

EX-13-05

- Q.** Please confirm that all CMP 345/115 kV autotransformers were not purchased with a 345/115 kV nominal voltage resulting in a .92 to 1.13 load tap changing range as indicated on 7/2/09. If this information is not correct, please supply the correct information.
- A.** All CMP 345/115 kV autotransformers have primary and secondary winding voltages of 345 kV and 118 kV, respectively.

Response Prepared & Submitted By:

David Conroy
Manager of System Planning
Central Maine Power Company