

**CENTRAL MAINE POWER COMPANY
RESPONSE TO FOURNIER'S DATA REQUEST NO. 1
DOCKET No. 2008-255**

October 23, 2008

FOURNIER-01-07

Q. Please give current Maguire Road Substation data regarding when it was built, any recent upgrades and what requirements for expansion are needed to utilize a proposed Section 3022, a new Section 250 and a new Section 197.

A. The Maguire Road substation was built, beginning in October 2007 with civil construction ending in September 2008 with the final tie-in of the last transmission line. There have been no upgrades since completion of the station in September of 2008.

The new proposed Section 3022 will require an expansion of the existing Maguire Road Substation to include 345 kV facilities. Section 250 does not require any expansion or modification at the Maguire Road Substation.

Section 197 does not terminate at Maguire Road Substation. It runs between Quaker Hill and Three Rivers.

Response Prepared By:
James N Begin P. E.
Project Manager

Response Submitted By:
Steve Walker, PE
POWER Engineers, Inc.