

**CENTRAL MAINE POWER COMPANY
RESPONSE TO FOURNIER'S DATA REQUEST NO. 2
DOCKET No. 2008-255**

November 10, 2009

FOURNIER-02-20

- Q.** On the proposed 345 kV, Section 3022 single steel pole, V-string design, how far from the center of the two existing poles of the existing Section 250 H-Frame poles, is the planned location of the steel poles?
- A.** The proposed centerline of Section 3022 is located along the existing centerline of Section 250, which is 75 ft. from the eastern edge of the transmission corridor.

Response Prepared and Submitted By:
Steve Walker, PE
POWER Engineers, Inc.