

**CENTRAL MAINE POWER COMPANY
RESPONSE TO INDUSTRIAL ENERGY CONSUMER GROUP'S DATA
REQUEST NO. 1
DOCKET No. 2008-255**

October 3, 2008

IECG-01-33

Q. Please describe how and why net energy revenues to existing Maine generators was calculated in table MPRP-5.

A. Net energy revenues were calculated for each existing generating unit by multiplying estimated output by LMPs and deducting estimated fuel costs to produce that output. The values were summed for all units to arrive at the figures in Table MPRP-5 on page 34 of Volume I of the Petition.

As noted in the response to EX-07-13, the owners of existing generating units in Maine are businesses that operate within the state. With the implementation of restructured electric markets in ISO-NE, load serving entities may have different interests than generation owners. La Capra Associates included the net energy revenues parameter in our analysis of Non-Transmission Alternatives to determine whether there was any adverse impact to existing generators. We consider this parameter to be less important than other parameters, such as societal costs or rate impacts. Based upon our results, the impact on existing generators was not significant.

Response Prepared and Submitted By:

Richard S. Hahn
Principal Consultant
La Capra Associates, Inc.

Daniel Peaco
President
La Capra Associates, Inc.