

**ISO NEW ENGLAND INC
RESPONSE TO HEARING EXAMINER ORAL DATA REQUEST NO 1.**

DOCKET NO. 2008-255

November 7, 2008

ODR-01- 29

Q: Transfer limits at interfaces in Maine – existing; thermal; stability

A: ODR 29: List the all lines in transfer limits across existing interfaces in Maine. List whether or not these are based on thermal, voltage, or stability concerns.

Interface	Limit*	Reason
New Brunswick - Maine	1000	Stability
Orrington – South	1200	New England source loss/Stability
Surowiec – South	1150	Stability
Maine – New Hampshire	1600	Thermal/Stability

*All values provided are approximate. System conditions such as varying generation patterns can alter these values.

Response Prepared and Submitted By:

Brent Oberlin
Transmission Planning
ISO New England Inc.