

**CENTRAL MAINE POWER COMPANY
RESPONSE TO ORAL DATA REQUEST NO. 1
DOCKET No. 2008-255**

December 5, 2008

ODR-01-86

- Q.** Please provide the 2005 actual load flows for Great Falls as well as any load adjustments.
- A.** The attached Excel workbook provides the approximate low flow for the Great Falls substation. The load is approximate because it is the difference between the flows in line sections 148 and 149, and thus includes the related line losses. The data is taken from the EMS and covers only the August to December period.

Response Prepared and Submitted By:

Paul Lerley
Engineer, System Planning
Central Maine Power Company

Attachment(s):

1. Great Falls 2005.xls