

**CENTRAL MAINE POWER COMPANY
RESPONSE TO ORAL DATA REQUEST NO. 2
DOCKET No. 2008-255**

November 13, 2008

ODR-02-05

Q. Please provide data on the last 10 years of vegetation management on Segments 18 and 19.

A. These transmission lines have been on a four year vegetation management cycle which CMP plans to continue. Each cycle year the entire ROW (right of way) is cleared of all capable tree species over two feet tall. Any screens within the ROW are either removed or pruned during the cycle year.

Section 375 was cleared in 2001 and 2005

Section 374 was cleared in 2002 and 2006

Section 166 was cleared in 2003 and 2007

Section 167 was cleared in 2003 and 2007

Section 102 was cleared in 2003 and 2007

Section 104 was cleared in 2004 and 2008

The vegetation management data for the last ten years in segments 18 & 19 is voluminous and will be made available for inspection at Central Maine Power Company's General Office by appointment. Please contact debra.mills@cmpco.com via e-mail or call (207) 626-9798 to make an appointment.

Response Prepared By:

Weston J. Davis

Manager of Vegetation Management Operations

Central Maine Power Company

Response Submitted By:

Mary Smith

Project Manager

Central Maine Power Company

Attachment:

1. Vegetation management data for Segments 18 and 19