

Winslow-Skowhegan		2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027
2032	longevity year																			
	90/10 Load	130.8	133.9	137.0	140.2	143.5	146.8	150.2	153.7	157.3	160.4	163.7	166.9	170.3	173.7	177.1	180.7	184.3	188.0	191.7
	relief to meet criteria								-											
	target net load level								153.7	153.7	153.7	153.7	153.7	153.7	153.7	153.7	153.7	153.7	153.7	153.7
	cum MW NTAs needed								-	3.6	6.7	9.9	13.2	16.5	20.0	23.4	27.0	30.6	34.3	38.0
	MVAR needed				90.0	5.0	5.0	5.0	-	1.1	1.0	1.0	1.0	1.1	1.1	1.1	1.1	1.2	1.2	1.2
	cum MVAR Added				90.0	95.0	100.0	105.0	105.0	106.1	107.1	108.2	109.2	110.3	111.4	112.5	113.6	114.8	115.9	117.1

Existing 20 MVAR capacitor at Haywood Rd

Winslow-Skowhegan

BUS-NO	NAME
70142	RICERIPS
70147	LAKEWOOD
70330	WINSLOW
70330	WINSLOW

		90/10 loads, MW		
ID	P2006	2012	2017	
1	30.0	34.9	40.2	
1	31.0	34.4	37.9	
I	23.1	24.3	25.6	
RC	40.0	46.5	53.6	
	124.1	140.2	157.3	

		90/10 loads, MVAR		
P2006	2012	2017		
9.0	10.5	12.1		
9.3	10.3	11.4		
10.7	10.7	10.7		
12.0	14.0	16.1		
41.0	45.4	50.2		

